



# DECLARATION OF CONFORMITY

Scott Safety, A Division of Scott Technologies, Inc.  
Monroe Corporate Center  
4320 Goldmine Road  
Monroe, NC 28110-7355 USA

Tel.: (704) 291-8300

Fax: (704) 291-8340

## For a Fixed Toxic Gas Transmitter / Detector



**MODELS:** Freedom 5600      **MANUFACTURER:** Scott Safety, A Division of Scott Technologies, Inc.  
Monroe Corporate Center  
4320 Goldmine Road  
Monroe, NC 28110-7355 USA  
Phone: (704) 291-8300 Fax: (704) 291-8340

**CONFIGURATIONS:** Two Wire, 4 – 20mA Type

**TECHNICAL FILE #:** Ex-1053

**DIRECTIVES:** ATEX Directive (94/9/EC)

**ATEX CERTIFICATE #:** LCIE 03 ATEX 6437X


**ATEX CODING:**   II 3 G Ex nA IIC T6 Gc (-20°C ≤ Tamb ≤ 50°C)

**STANDARDS:** EN 60079-0 :2009      EN 60079-15 :2010

**ATEX Notified Body:** LCIE Bureau Veritas  
33, avenue du Général Leclerc  
92260 Fontenay-aux-Roses  
France

We declare, under our sole responsibility, that the Model Freedom 5600 Fixed Toxic Gas Transmitter / Detector, configuration Two wire, 4 – 20mA type to which this declaration relates is in conformance with the ATEX Directive 94/9/EC and the standards referenced above when properly installed and maintained and when used for the purpose for which it is intended.

Authorized by:



Name: John Franco

Title: Senior Operations Manager

### Special Conditions for Safe Use

1. Unchanged.